



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3045094
Permit #: 01155-2023UPG
Request Rec'd: 10/05/2023
Approval Date: 10/05/2023 DS
Permit Expires: 04/05/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Metropolitan Airport Authority 2200 69th Ave. Moline, IL 61265 Rock Island County Contact: Andrew McVietty 309/757-1736 | FACILITY - name and address where tanks are located: Metropolitan Airport Authority 6300 75th Avenue Milan, IL 61264 Rock Island County Contact: Andrew McVietty 309/314-1271 |
|---|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|---------------|----------|------------------|------------------|
| 2 | Aviation Fuel | 10,000 | Currently in use | Federal |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|--------------------------|---|
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Summary of Work

Replacing spill bucket with double wall spill bucket

Special Contingencies

| | |
|---|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Pipeco, Inc. 610 29th Street Bettendorf, IA 52722 | Contact Person: Robert Schafer Phone: 563/529-8502 Email: rob@pipoecoinc.com Contractor License # IL2034 Exp. 9/28/2024 |

Sincerely,

Daniel Starks