



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 7011098
Permit #: 01156-2023REM
Request Rec'd: 10/05/2023
Approval Date: 10/05/2023 DS
Permit Expires: 04/05/2024

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Kinkaid-Reeds Creek Conservancy District 1763 Water Plant Road Murphysboro, IL 62966 Jackson County Contact: Scott Wilmouth 618/687-1722 | FACILITY - name and address where tanks are located: Kinkaid Marina 2063 Marina Road Murphysboro, IL 62966 Jackson County Contact: Scott Wilmouth 618/687-1722 |
|--|---|

Tanks on the Permit For Piping Only

| Tank # | Capacity | Product | Last Used Date |
|--------|----------|------------------------|----------------|
| 3 | 10,000 | Gasoline - Non Ethanol | |

Summary of Work

Removal of piping ONLY

approximately 200' of piping from tank to the transition sump located by waters edge (sump to remain)

approximately 140' of piping from tank to the dispenser under canopy (island and canopy to remain)

Excavate down to top of tank for disconnect of piping from submerged pump in sump

New piping will be done on another permit

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

| | |
|---|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Robert Ellis & Sons 1703 North 7th Street Murphysboro, IL 62966 | Contact Person: Mike Ellis Phone: 618/713-0765 Email: ellisexcavating35@live.com Contractor License # IL980 Exp. 3/23/2024 |

Sincerely,

Daniel Starks