



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Revised

FOR OFFICE USE ONLY
Facility #: 2047629
Permit #: 01135-2023ABN
Request Rec'd: 10/02/2023
Approval Date: 10/02/2023
Extension Date: 10/05/2023
Permit Expires: 04/02/2024

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: City of Chicago 2 N. LaSalle Street, Ste. 200 Chicago, IL 60602 Cook County Contact: Heidi Keller 312/744-2468	FACILITY - name and address where tanks are located: 3536 W Ogden 3536 W Ogden Ave Chicago, IL 60623 Cook County Contact: Sarah Rubin 312/744-3639
--	---

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
3	550	Lube Oil	Inert material mixed with portland cement	
4	550	Lube Oil	Inert material mixed with portland cement	tank is within 5' of utility pole

Explanation of Waiver for Abandonment

UST was discovered within 5' of a electric pole and needs to be abandoned-in-place.

Special Contingencies

Revision Reason:

Add tank #3 to permit

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2024

Sincerely,

Raul Valdivia