



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 5021005
Permit #: 01162-2023ABN
Request Rec'd: 10/06/2023
Approval Date: 10/07/2023 SB
Permit Expires: 04/09/2024

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Illinois Department of Corrections 1301 Concordia Court P.O. Box 19277 Springfield, IL 62703 Sangamon County Contact: Jeff Short 217/735-5581	FACILITY - name and address where tanks are located: Logan Correctional Center 1096 1350th Street Lincoln, IL 62656 Logan County Contact: Duane Sparks 217/735-5581
---	--

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
6	2,500	Diesel Fuel	Inert material mixed with portland cement	

Explanation of Waiver for Abandonment

The tank #6 is located in the tank field with tanks #4 and #5. Tanks #4 and #5 are going to be still used at the facility. Removal of tank #6 would potentially damage tanks #4 and #5. At such time that tanks #4 and #5 are taken out of service and removed, the abandoned tank #6 would be removed too.

Location of Tanks Being Abandoned

<p>See attached drawing for location of tank #6.</p>

Special Contingencies

It would be infeasible to remove tank #6 at this time due to disruption of tanks 4 & 5. (They are all in the same tank bed). This tank must be removed when the condition for issuing the abandonment permit no longer exists (i.e., whenever it is decided to remove tanks 4 & 5, then tank #6 must be removed too).

PERSON, FIRM OR COMPANY PERFORMING WORK:	
CW3M Company, Inc. 701 West South Grand Avenue Springfield, IL 62704	Contact Person: Carol Rowe Phone: 217/522-8001 Email: todrowe66@gmail.com Contractor License # IL1723 Exp. 8/9/2024

Sincerely,

Shelly Bradley