



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 2018007  
Permit #: 01164-2023UPG  
Request Rec'd: 10/08/2023  
Approval Date: 10/10/2023 DS  
Permit Expires: 04/10/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|  |  |
|--|--|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Mansour & Mona Saed<br>1100 Belvidere Rd.<br>Waukegan, IL 60085<br>(None) County<br>Contact: Mansour Saed 847/662-7890 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Swif-T 2, Inc.<br>1100 Belvidere Rd<br>Waukegan, IL 60085<br>Lake County<br>Contact: Mansour Saed 847/662-7890 |
|--|--|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 9      | Gasoline - Regular | 12,000   | Currently in use | Federal          |
| 10     | Gasoline - Regular | 10,000   | Currently in use | Federal          |
| 11     | Diesel Fuel        | 10,000   | Currently in use | Federal          |
| 12     | Gasoline - Premium | 6,000    | Currently in use | Federal          |
| 13     | Kerosene           | 1,000    | Currently in use | Federal          |

**Tank 9 Equipment**

| Equipment Type        | Permit Equipment                                     | Action  |
|-----------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 |

**Tank 10 Equipment**

| Equipment Type        | Permit Equipment                                     | Action  |
|-----------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 |

**Tank 11 Equipment**

| Equipment Type        | Permit Equipment                                     | Action  |
|-----------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 |

**Tank 12 Equipment**

| Equipment Type        | Permit Equipment                                     | Action  |
|-----------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 |

**Tank 13 Equipment**

| Equipment Type        | Permit Equipment                                     | Action  |
|-----------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 350 with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 |


**Summary of Work**

Install CSLD chip in TLS 350 Tank Monitor.

**Special Contingencies**

| PERSON, FIRM OR COMPANY PERFORMING WORK:                                     |  |
|--|--|
| Cardinal Compliance LLC<br>1058 National Parkway<br>Schaumburg, IL 601734519 | Contact Person: Chris Derro<br>Phone: 708/717-2676<br>Email: cderro@cardinalcompliance.net<br>Contractor License # IL002418 Exp. 3/21/2025 |

Sincerely,



Daniel Starks