



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 5017274
Permit #: 01173-2023CAT
Request Rec'd: 10/10/2023
Approval Date: 10/10/2023 DS
Permit Expires: 04/10/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Jayvir, Inc. 101 E. Union Avenue Litchfield, IL 62056 Montgomery County Contact: Sanjay Patel 847/208-5396	FACILITY - name and address where tanks are located: Amstar 101 E. Union Avenue Litchfield, IL 62056 Montgomery County Contact: Sam Patel 217/324-4641
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	6,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection
Corrosion Protection - Piping	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection

NACE Certified Designer

NACE Certified Designer Number

Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

DIG TO TOP OF TANK AT SUBMERGE PUMP AND INSTALL CONNECTION TO GROUND WIRE. RUN GROUND WIRE TO THE IMPRESSED CURRANT SYSTEM IN SIDE BIULDING.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
R. L. Hoener Company 2923 Gardner Expressway P. O. Box 1086 Quincy, IL 62305	Contact Person: Marty Jackson Phone: 217/223-2190 Email: marty@rlhoener.com Contractor License # IL2021 Exp. 5/22/2024

Sincerely,

Daniel Starks