



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2020409
Permit #: 01180-2023UPG
Request Rec'd: 10/11/2023
Approval Date: 10/11/2023 DS
Permit Expires: 04/11/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Samer T. Farhan 8728 W. 98th Place Palos Hills, IL 60465 Cook County Contact: Samer Farhan 708/277-5708	FACILITY - name and address where tanks are located: BP Gas 1812 Sibley Blvd. Calumet City, IL 60409 Cook County Contact: Samer Farhan 708/277-5708
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Diesel Fuel	8,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Fiberglass Single Wall Piping Ameron	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Other Submersible Pump	New
Piping	Other Steel Riser	New
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Single Wall STP/Tanktop Sump	New

Summary of Work

The Diesel fueling system will be converted to E85 product which will require a containment sump addition at the STP and the changing of the tank probe and float, line leak detector, ball valve, flex connector, overfill prevention drop tube, and approximately 5 lf. of singlewall fiberglass pipe.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Daniel G. Starks

Daniel Starks

For Office Use Only

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing