



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3027019
Permit #: 01188-2023REM
Request Rec'd: 10/16/2023
Approval Date: 10/16/2023 DS
Permit Expires: 04/16/2024

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: BG Mini Mart, Inc. 502 1st Avenue Colona, IL 61241 (None) County Contact: Ganga Prasai 309/792-3030	FACILITY - name and address where tanks are located: BG Mini Mart, Inc. Shell Station #1185 502 1st Avenue P.O. Box 74 Colona, IL 61241 Henry County Contact: Ganga Prasai 309/792-3030
---	--

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
4	8,200	Gasoline - Mid-grade	04/12/2023
5	8,200	Gasoline - Regular	04/12/2023
6	4,000	Diesel Fuel	04/12/2023
7	4,000	Gasoline - Premium	04/12/2023

Summary of Work

We will be removing all of the existing tank top fittings from the existing tanks. the vents will stay as the are. We will be removing the old underground piping from the existing STP'S out to the existing UDC and the transition sump under the existing canopy. We are not sure how the existing piping is running but we will be able to follow it because all of the concrete is being removed on top of the tanks and under the canopy. We will be replacing the piping with new APT 150XP Double wall flexible, the UDC are APT poly single wall sumps, and the tank top STP Sumps are single wall poly APT. Everything will have Veeder Root discriminating sensors installed, with positive shut down.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pipeco, Inc. 610 29th Street Bettendorf, IA 52722	Contact Person: Robert Schafer Phone: 563/529-8502 Email: rob@pipecoinc.com Contractor License # IL2034 Exp. 9/28/2024

Sincerely,

Daniel G. Starks

Daniel Starks