



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2016454
Permit #: 01193-2023UPG
Request Rec'd: 10/17/2023
Approval Date: 10/17/2023
Permit Expires: 04/17/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Taisir Realty, LLC 5616 S. Western Ave. Chicago, IL 60636 Cook County Contact: Sam Fahan 269/208-3207 | FACILITY - name and address where tanks are located: Cigto Gas Station 5600-16 S. Western Avenue Chicago, IL 60636 Cook County Contact: Sam Fahan 269/208-3207 |
|---|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 9 | Gasoline - Regular | 20,000 | Currently in use | Federal |
| 10 | Gasoline - Premium | 10,000 | Currently in use | Federal |

Tank 9 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--------------------------|---|
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |

Tank 10 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------|--------------------------|---|
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |

Summary of Work

Replacing single wall spill buckets on RUL and PUL with double wall spill buckets. Replacing RUL and PUL drop tubes. Boot repair under dispenser 1/2 and 3/4.

Special Contingencies

| | |
|---|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| B & K Equipment Company 2939 175th Street Lansing, IL 60438 | Contact Person: Ed Angell Phone: 708/474-3344 Email: ben.olthoff@bkequip.com Contractor License # IL1207 Exp. 2/14/2024 |

Sincerely,

Seán Keane

Raul Valdivia