



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY

Facility #: 2038856
Permit #: 01072-2023UPG
Request Rec'd: 09/19/2023
Amended Date: 10/18/2023 DS
Approval Date: 09/20/2023 DS
Permit Expires: 03/20/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Swift Transportation Company, Inc. 2200 South 75th Avenue Phoenix, AZ 85043 (None) County Contact: Joseph Manley 602/907-3473	FACILITY - name and address where tanks are located: Swift Transportation Company, Inc. 1215 Boudreau Road Manteno, IL 60950 Kankakee County Contact: Steve Brouwer 602/907-3473
---	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	15,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall A.P.T. Poly Tech P175SC	Replacing - Piping - Flexible Double Wall A.P.T. Poly Tech P175SC

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Summary of Work

Replacing existing piping with XP175-SC piping.

Special Contingencies

Replaced piping exceeds 20 feet or 50% of the total pipe run.

Amendment Reason:

The UDC sump was omitted from this Upgrade permit and needs to be added. We are replacing 1- UCD sump (LMM2313T) due to it is cracked and needs to be replaced. Thank you.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Pemco Service Company, Inc.
1040 East Second Street
Gilman, IL 60938

Contact Person: William "Butch" VonDrehle
Phone: 217/822-8628
Email: cmoore52@frontier.com
Contractor License # IL1224 Exp. 2/26/2024

Sincerely,



Daniel Starks