

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 5040225
Permit #: 01196-2023UPG
Request Rec'd: 10/18/2023
Approval Date:10/18/2023 DS
Permit Expires: 04/18/2024

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Pilot Travel Centers, LLC 5508 Lonas Rd.

Knoxville, TN 37909

**Knox County** 

Contact: Joey Cupp 865/588-7488

**FACILITY** 

- name and address where tanks are located:

Mr. Fuel #1245 4th Corvette Drive Litchfield, IL 62056 Montgomery County

Contact: Joey Cupp 865/588-7488

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	15,000	Currently in use	Federal

### **Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

### **Summary of Work**

Need upgrade permit for Tank 2 diesel to change to OPW 1c-3112d bucket. Re using drop tube and just changing bucket.

#### **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4618 Email: HEATHER_HINDS@NEUMAYEREQUIPMENT.COM Contractor License # IL1502 Exp. 3/26/2024			

Sincerely, Daniel J. Starks

Daniel Starks