



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Revised**

**FOR OFFICE USE ONLY**

Facility #: 2008993  
Permit #: 01198-2023UPG  
Request Rec'd: 10/18/2023  
Approval Date: 10/18/2023 DS  
Extension Date: 10/18/2023  
Permit Expires: 04/18/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: 67 W 79 Burbank, LLC 1983 Route 52 Hopewell Junction, NY 12533 (None) County Contact: Patty Garcia 845/765-8507	<b>FACILITY</b> - name and address where tanks are located: 6027 W 79 Burbank, LLC 6027 West 79th Street Burbank, IL 60459 Cook County Contact: Ibrahim Sallah 347/499-3835
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Gasoline - Premium	8,000	Currently in use	Federal

**Tank 8 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Ball Valves	Replacing - Piping - Fiberglass Single Wall Piping
Piping	Other Submersible Pump	New
Piping	Flex Connector Steel	New

**Dispensers on the Permit**

Dispenser	Action
1/2	Replacing - 1/2
3/4	Replacing - 3/4
5/6	Replacing - 5/6
7/8	Replacing - 7/8

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

**Dispenser 5/6 Equipment**

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

**Dispenser 7/8 Equipment**

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

**Summary of Work**

Converting the Premium tank to E85. Replacing the submersible motor, ball valves, drop tube, probe, and 4 dispensers. Site has existing STP containment and UDC containment.

**Special Contingencies****Revision Reason:**


New UDCs will not be installed, the existing will remain

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company  
2939 175th Street  
Lansing, IL 60438

Contact Person: Ed Angell  
Phone: 708/474-3344  
Email: jim.veverka@bkequip.com  
Contractor License # IL1207 Exp. 2/14/2024

Sincerely,



Daniel Starks