



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Extended/Revised

FOR OFFICE USE ONLY

Facility #: 2047519
Permit #: 01237-2022INS
Request Rec'd: 11/09/2022
Approval Date: 11/09/2022 DS
Extension Date: 10/18/2023
Permit Expires: 11/09/2023

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	FACILITY - name and address where tanks are located: Casey's General Stores #3969 25235 W. Eames Street Channahon, IL 60410 Will County Contact: Lee Lytle 515/446-6231
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	22,000	Installed/Not in Use	Federal
2	B-11	14,000	Installed/Not in Use	Federal
3	E15	8,000	Installed/Not in Use	Federal
4	Gasoline - Premium	8,000	Installed/Not in Use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Single Wall Spill Bucket	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Corrosion Protection - Tank	Fiberglass Non-Corrosive	New
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Tank	Fiberglass Double Wall	New
Piping	Flexible Double Wall A.P.T. Poly Tech S175SC	New
Piping	Single Wall STP/Tanktop Sump	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Single Wall Spill Bucket	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Corrosion Protection - Tank	Fiberglass Non-Corrosive	New
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Tank	Fiberglass Double Wall	New
Piping	Flexible Double Wall A.P.T. Poly Tech S175SC	New
Piping	Single Wall STP/Tanktop Sump	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Single Wall Spill Bucket	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Corrosion Protection - Tank	Fiberglass Non-Corrosive	New
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Tank	Fiberglass Double Wall	New
Piping	Flexible Double Wall A.P.T. Poly Tech S175SC	New
Piping	Single Wall STP/Tanktop Sump	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	New
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Single Wall Spill Bucket	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Corrosion Protection - Tank	Fiberglass Non-Corrosive	New
Corrosion Protection - Piping	Flexible Non-Corrosive	New
Tank	Fiberglass Double Wall	New
Piping	Flexible Double Wall A.P.T. Poly Tech S175SC	New
Piping	Single Wall STP/Tanktop Sump	New

General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions.

There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Summary of Work

Installing (1) 30,000 gallon (split 22/8) and (1) 22,000 gallon (split 14/8/8) double wall fiberglass tanks. New tank sumps and dispenser sumps. APT double wall product piping to (6) fuel islands. All islands will have diesel fuel and all islands will have E85. Vent pipe to be single wall fiberglass. New Veeder Root TLS 450 Plus with mag plus probes, sump sensors, interstitial sensors, and plld's.

Special Contingencies

NOTE: A motor fuel dispensing permit must be applied for asap

Amendment Reason:


There is no E85 tank being installed at this location Reassign T3 as E-15.

Revision Reason:

Tank 3 product change to E15 and owner decided to not install tank 5

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company 1111 West Dundee Road Wheeling, IL 600903936	Contact Person: Warren Cherner Phone: Email: Contractor License # IL102 Exp. 2/7/2024

Sincerely,



Daniel Starks