



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2023961
Permit #: 01208-2023UPG
Request Rec'd: 10/19/2023
Approval Date: 10/19/2023 DS
Permit Expires: 04/19/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: FedEx Ground Pkg. System, Inc. 1000 FedEx Drive FedEx Ground, Environmental Moon Township, PA 15108 (None) County Contact: Antony Spalvieri 412/859-2384	FACILITY - name and address where tanks are located: FedEx Ground - Chicago 6833 W. 75th Street Bedford Park, IL 60638 Cook County Contact: Steve DiGrazia 708/728-3770
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Diesel Fuel	20,000	Currently in use	Federal

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Piping	Shear Valves	New

Summary of Work

Replace spill container single wall with double wall, drop tube and sshear valve on dispenser 3.

Special Contingencies

NOTE: A UDC must be installed under dispenser 3 if one doesn't already exist

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/243-9081 Email: Steve@andersonpump.com Contractor License # IL002275 Exp. 5/21/2024

Sincerely,

Daniel Starks