



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2014703
Permit #: 01206-2023UPG
Request Rec'd: 10/18/2023
Approval Date: 10/19/2023
Permit Expires: 04/22/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 3700 W 111, LLC 1983 Route 52 Hopewell Junction, NY 12533 (None) County Contact: Patty Garcia 845/765-8507	FACILITY - name and address where tanks are located: 3700 W 111, LLC 3700 W. 111th Chicago, IL 60655 Cook County Contact: Ibrahim Sallah 347/499-3835
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	12,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Gilbarco EMC with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Gilbarco EMC with CSLD
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	New
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000/L	New
Piping	Ball Valves	New
Piping	Flex Connector Steel	New

Summary of Work

Converting Premium tank to E85. Replacing submersible motor, ball valve, flex connector, drop tube, and probe. Installing tanktop sump where one does not exist due to the replacement of the submersible motor.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: jim.veverka@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

Seán Keane

Raul Valdivia

For Office Use Only

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing