

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2006903
Permit #: 01216-2023LIN
Request Rec'd: 10/22/2023
Approval Date:10/22/2023 DS
Permit Expires: 04/23/2024

# <u>Permit for INSPECTION OF INTERIOR LINING of Underground Storage Tank(s) for Petroleum and Hazardous Substances</u>

Permission to inspect existing interior lining of underground storage tank(s) is hereby granted. Such inspections of interior lining must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. **THIS PERMIT IS FOR THE INTERIOR INSPECTION OF THE EXISTING LINING ONLY! NO REPAIRING, UPGRADING, OR INTERIOR LINING IS AUTHORIZED WITH THIS PERMIT.** 

### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Roosevelt & Cicero Property, LLC 4809 W. Roosevelt Road

Cicero, IL 60804 (None) County

Contact: Ammar Alesayi 708/655-9265

**FACILITY** 

- name and address where tanks are located:

Cicero Food & Fuel, Inc. 4801 W. Roosevelt Rd. Cicero, IL 60804 Cook County

Contact: Ammar Alesayi 708/655-9265

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status	Manway
1	Gasoline - Regular	10,000	Currently in use	Federal	Existing
2	Gasoline - Premium	10,000	Currently in use	Federal	Existing
3	E85	8,000	Currently in use	Federal	Existing

## **Summary of Work**

Purge, clean, re-inspect, and re-certify the internal lining of the following tanks in accordance with State of Illinois 175 regulations and NLPA-631 requirements.

# **Special Contingencies**

Janiel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Armor Shield of Wisconsin 3965 Hillside Road Slinger, WI 53086	Contact Person: Clayton Bennett Phone: 262/623-0300 Email: paula@armorshieldus.com Contractor License # IL1707 Exp. 4/18/2024			

Sincerely,

Daniel Starks