



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Revised**

**FOR OFFICE USE ONLY**

Facility #: 2047583  
Permit #: 01185-2023UPG  
Request Rec'd: 10/13/2023  
Approval Date: 10/13/2023 SB  
Extension Date: 10/22/2023  
Permit Expires: 04/15/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|  |  |
|--|--|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Thorntons LLC<br>2600 James Thornton Way<br>Louisville, KY 40245<br>Jefferson County<br>Contact: Maggie Seagh 502/425-8022 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Thornton's Store #356<br>500 West Maple Street<br>New Lenox, IL 60451<br>Will County<br>Contact: Maggie Sebaugh 502/425-8022 |
|--|--|

**Tanks on the Permit For Piping Only**

| Tank # | Product            | Capacity | Tank Status          | Regulated Status |
|--------|--------------------|----------|----------------------|------------------|
| 1      | Gasoline - Regular | 20,000   | Installed/Not in Use | Federal          |
| 2      | Gasoline - Premium | 6,000    | Installed/Not in Use | Federal          |
| 3      | E85                | 6,000    | Installed/Not in Use | Federal          |
| 4      | Diesel Fuel        | 10,000   | Installed/Not in Use | Federal          |

**Tank 1 Equipment**

| Equipment Type | Permit Equipment   | Action  |
|----------------|--|---|
| Piping         | Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping | Replacing - Piping - Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping |

**Tank 2 Equipment**

| Equipment Type | Permit Equipment   | Action  |
|----------------|--|---|
| Piping         | Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping | Replacing - Piping - Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping |

**Tank 3 Equipment**

| Equipment Type | Permit Equipment   | Action  |
|----------------|--|---|
| Piping         | Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping | Replacing - Piping - Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping |

#### Tank 4 Equipment

| Equipment Type | Permit Equipment   | Action  |
|----------------|--|---|
| Piping         | Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping | Replacing - Piping - Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping |

#### Summary of Work

Replace 20 feet of piping on all products that was damaged.

#### Special Contingencies

This is a brand new tank install facility. The new piping that was recently installed was damaged when a concrete driver drove over it. Licensed contractor was told to apply for a new upgrade permit to install replacement piping.

Replaced piping exceeds 20 feet or 50% of the total pipe run.

#### Revision Reason:

Name of facility was updated

#### PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.  
19659 South 97th Avenue  
Mokena, IL 60448

Contact Person: Ron Anderson  
Phone: 708/243-9081  
Email: Steve@andersonpump.com  
Contractor License # IL002275 Exp. 5/21/2024

Sincerely,



Shelly Bradley