

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety 1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov

SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

 Facility #:
 2001602

 Permit #:
 01219-2023UPG

 Request Rec'd:
 10/23/2023

 Approval Date:
 10/23/2023 DS

 Permit Expires:
 04/23/2024

# Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

## THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	FACILITY - name and address where tanks are located:
Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083 Lake County	Bensenville #198 101 W. Irving Park Rd. Bensenville, IL 60106 Du Page County
Contact: John Graham 847/223-3710	Contact: Julio Martinez 630/594-4903

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Kerosene	2,000	Currently in use	Federal

## **Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flexible Single Wall Piping	Replacing - Piping - Fiberglass Single Wall Piping

## Summary of Work

Replacing the existing vent / vapor extractor on the existing K1 tank as well as the existing K1 vent piping with new Nupi 2" SW Semi-Rigid piping to the parkway area East of tank. Installing new vent rack with 2" Stainless Steel vent riser extending 12' above existing grade.

## **Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:			
Performance Tank, Inc. 730 Creel Drive Wood Dale, IL 60191	Contact Person: Tim Berg Phone: 847/612-6551 Email: tberg@perftank.com Contractor License # IL881 Exp. 12/8/2024		

Sincerely,

niel J. Starke

Daniel Starks