



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 6011117  
Permit #: 01220-2023UPG  
Request Rec'd: 10/19/2023  
Approval Date: 10/23/2023 DS  
Permit Expires: 04/23/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Moto, Inc. 721 W. Main Street Belleville, IL 62222 St. Clair County Contact: Shane Maxey 616/233-6754	<b>FACILITY</b> - name and address where tanks are located: Freeburg Moto Mart #3111 751 South State Street Freeburg, IL 62243 St. Clair County Contact: David Reiniger 618/539-5509
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	20,000	Currently in use	Federal
7	Gasoline - Premium	20,000	Currently in use	Federal
8	Diesel Fuel	12,000	Currently in use	Federal

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	Replacing - Leak Detect - Piping - Sump Sensor
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Flexible Double Wall

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Flexible Double Wall
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	Replacing - Leak Detect - Piping - Sump Sensor

## Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

## Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing
9/10	Sump / Sensors Changing

## Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor	Reusing Existing

## Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

## Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

## Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

## Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New


## Summary of Work

Replacing all dispenser sumps and STP sumps. The Regular and Premium product piping will be replaced with APT XP 150SC doublewall flexible piping. Piping will be pulled in through the existing chase pipe. Positive shut down sump sensors will be installed. A removal permit will be applied for.

## Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/241-3767 Email: terrys@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2024

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**For Office Use Only**

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed	Review

**Dispenser 5/6 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed	Review

**Dispenser 7/8 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed	Review

**Dispenser 9/10 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed	Review