



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 1038612  
Permit #: 01225-2023UPG  
Request Rec'd: 10/23/2023  
Approval Date: 10/23/2023 DS  
Permit Expires: 04/23/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	<b>FACILITY</b> - name and address where tanks are located: Casey's General Store #2248 900 E. Market St. Somonauk, IL 60552 De Kalb County Contact: Laura Charles 515/965-6238
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
2	B-11	10,000	Currently in use	Federal

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

B-11 Drop tube seized. Replaced drop tube, upgraded to DW spill bucket.  
Drop tube set to 95% fill capacity, flapper moves freely  
DW bucket shows passing hydro test results  
Work performed 8/14/23

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: trevorh@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

Daniel Starks