



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2026178
Permit #:	01226-2023UPG
Request Rec'd:	10/24/2023
Approval Date:	10/24/2023 DS
Permit Expires:	04/24/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Graham C-Stores Co. 39109 N. US Hwy 41 Wadsworth, IL 60083 Lake County Contact: John Graham 847/223-3710	FACILITY - name and address where tanks are located: Yorkville #204 1402 N. Bridge Street Yorkville, IL 60560 Kendall County Contact: Robert Kopchik 847/223-3710
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	20,000	Currently in use	Federal
5	Gasoline - Premium	15,000	Currently in use	Federal
6	Diesel Fuel	12,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall A.O. Smith	Replacing - Piping - Fiberglass Double Wall A.O. Smith

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall A.O. Smith	Replacing - Piping - Fiberglass Double Wall A.O. Smith

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall A.O. Smith	Replacing - Piping - Fiberglass Double Wall A.O. Smith

Summary of Work

We will be breaking out an area of concrete around the existing STP Sumps and excavating areas to expose the existing DWFRP piping at the existing STP Sump walls. We will be cutting back the existing DWFRP a few feet away from the existing sump walls, removing the existing penetration fitting and installing new pass through FRP penetration fitting. We will then install new DWFRP pipe routed back into sump, through new penetration fittings, install test reducer fittings and connect piping back to the existing STP's.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Performance Tank, Inc.
730 Creel Drive
Wood Dale, IL 60191

Contact Person: Tim Berg
Phone: 847/612-6551
Email: tberg@perftank.com
Contractor License # IL881 Exp. 12/8/2024

Sincerely,



Daniel Starks