



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 6041636
Permit #: 01229-2023UPG
Request Rec'd: 09/25/2023
Approval Date: 10/24/2023 DS
Permit Expires: 04/24/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Midwest Petroleum Company 220 Old Meramec Station Rd. Manchester, MO 63021 (None) County Contact: Tony Koenig 636/220-3800	FACILITY - name and address where tanks are located: MPC #33 1291 Frank Scott Parkway West Belleville, IL 62223 St. Clair County Contact: Erik D. Ilgenfritz 314/647-5550
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
2	Gasoline - Premium	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

Summary of Work

Remove the dispenser from the island. Remove the gas dog bone island. Pour the concrete back with a 1" riase and no island. Replace the flex pipe to the shear value with a shorter flex. Put the dispenser back in. Preform line test.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
JDM Petroleum Service 220 Meramec Station Rd Manchester, MO 63021	Contact Person: Dennis Hoback Phone: 618/792-8818 Email: Dennis.hoback@jdmpetro.com Contractor License # IL002451 Exp. 7/15/2025

Sincerely,

Daniel Starks