



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2010062
Permit #: 01236-2023UPG
Request Rec'd: 10/24/2023
Approval Date: 10/24/2023 DS
Permit Expires: 11/06/2023

Permit for Emergency Repair Request on 10/24/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR TEN WORKING DAYS FROM THE APPROVAL DATE.

| | |
|---|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Sufi Mehtab, LLC / Ishakaehmad M. Vahora 733 E. 142nd Street Dolton, IL 60419 Cook County Contact: Firoz Vohra 708/574-2714 | FACILITY - name and address where tanks are located: Sufi Mehtab, LLC / Clark 733 E. 142nd Street Dolton, IL 60419 Cook County Contact: Firoz Vohra 708/574-2714 |
|---|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 5 | Gasoline - Premium | 12,000 | Currently in use | Federal |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------|----------------------|--------|
| Piping | Flex Connector Steel | New |

Summary of Work

A leak was discovered in the flex connector of the Premium STP sump. Will be replacing the flex connector.

Special Contingencies

| | |
|---|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| B & K Equipment Company 2939 175th Street Lansing, IL 60438 | Contact Person: Ed Angell Phone: 708/363-3345 Email: ben.olthoff@bkequip.com Contractor License # IL1207 Exp. 2/14/2024 |

Sincerely,

Daniel Starks