

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 7006061
Permit #: 01238-2023UPG
Request Rec'd: 10/25/2023
Approval Date:10/25/2023 DS
Permit Expires: 04/25/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606

(None) County

Contact: Elizabeth Patterson 984/389-1765

FACILITY

- name and address where tanks are located:

Circle K #4701209 2701 Broadway Mount Vernon, IL 62864 Jefferson County

Contact: Elizabeth Patterson 984/389-1765

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|---------|----------|------------------|------------------|
| 12 | B-11 | 6,000 | Currently in use | Federal |

Tank 12 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|------------------------------------|---|
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| →Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | | | | |
|--|--|--|--|--|
| Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139 | Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2024 | | | |

Sincerely, Daniel J. Starks

Daniel Starks