

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov Amended FOR OFFICE USE ONLY

Facility #: 7043712
Permit #: 01243-2023UPG
Request Rec'd: 10/25/2023
Amended Date:10/26/2023 DS
Approval Date: 10/25/2023 DS
Permit Expires: 04/25/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909

Knox County

Contact: Joey Cupp 865/588-7488

FACILITY

- name and address where tanks are located:

Contact: Aubrey Carter 865/588-7488Ext.2022

Pilot Travel Center #482 4610 Broadway

Mount Vernon, IL 62864 Jefferson County

refressor country

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	20,000	Currently in use	Federal
3	Diesel Fuel	20,000	Currently in use	Federal
6	Gasoline - Premium	12,000	Currently in use	Federal
7	Diesel Fuel	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53VML

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	New

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53VML

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53VML

Summary of Work

upgradeing overfill protection from ball and cage to overfill drop tubes

Special Contingencies

Amendment Reason:

TANK 3 UPGRADE PERMIT TO OVERFILL VALVE OPW 71S0-410C TANK 1 UPGRADE PERMIT TO OVERFILL VALVE OPW 71S0-410C

PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.

Daniel J. Starke

5060 Arsenal Street St. Louis, MO 63139 Contact Person: Jimmy Spiros

Phone: 314/772-4501

Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2024

Sincerely,

Daniel Starks