



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 5013583
Permit #: 01256-2023UPG
Request Rec'd: 10/30/2023
Approval Date: 10/30/2023 DS
Permit Expires: 04/30/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Bunn Capitol Company, LLC 1400 Stevenson Drive c/o Transportation Department Springfield, IL 62703 Sangamon County Contact: Matt Crocker 217/585-7552	FACILITY - name and address where tanks are located: Bunn Capitol Company, LLC 1212 Stevenson Dr. Springfield, IL 62703 Sangamon County Contact: Matt Crocker 217/585-7552
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Diesel Fuel	12,000	Currently in use	Federal
6	Diesel Fuel	4,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Omntec Proteus-K (OEL8000IIK4)	Replacing - Leak Detect - Tank - Automatic Tank Gauging Omntec OEL 8000 II

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Omntec Proteus-K (OEL8000IIK4)	Replacing - Leak Detect - Tank - Automatic Tank Gauging Omntec OEL 8000 II

Summary of Work

Replace existing tank gauge with similar but more modern tank gauge. allow tank gauge to run its testing and get a final inspection. Site does not have existing sensors in the STP sump or the dispenser sumps.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
W J Scott Company 3861 Tozer Road Springfield, IL 62707	Contact Person: Jim Scott Phone: 217/787-6081 Email: serwjs@comcast.net Contractor License # IL1949 Exp. 4/18/2024

Sincerely,

Daniel G. Starks

Daniel Starks