



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3026528
Permit #: 01260-2023REM
Request Rec'd: 10/31/2023
Approval Date: 10/31/2023 DS
Permit Expires: 04/30/2024

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: AM PM 125, Inc. 1012 E. Broadway P.O. Box 855 Astoria, IL 61501 (None) County Contact: Gopal Basnet 217/306-2920	FACILITY - name and address where tanks are located: AM PM 125, Inc. 1012 East Broadway P.O. Box 93 Astoria, IL 61501 Fulton County Contact: Everest Thapa 512/818-7199
--	--

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
1	6,000	Gasoline - Regular	
2	4,000	Gasoline - Premium	
3	4,000	Diesel Fuel	

Summary of Work

REMOVE EXISTING FIBERGLASS PIPING AND ISLANDS TO INSTALL NEW DOUBLE WALL PIPING AND SUMPS.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
R. L. Hoener Company 2923 Gardner Expressway P. O. Box 1086 Quincy, IL 62305	Contact Person: Marty Jackson Phone: 217/223-2190 Email: KMAJORS@RLHOENER.COM Contractor License # IL2021 Exp. 5/22/2024

Sincerely,

Daniel Starks