



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2045627
Permit #:	01266-2023UPG
Request Rec'd:	10/24/2023
Approval Date:	11/01/2023 DS
Permit Expires:	05/01/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Costco Wholesale Corporation P.O. Box 35005 Seattle, WA 98124 (None) County Contact: Jay Grubb 425/251-6222	FACILITY - name and address where tanks are located: Costco Gasoline #383 7220 Melvina Ave Niles, IL 60714 Cook County Contact: Repson Yong 847/647-2188
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Premium	30,000	Currently in use	Federal
4	Ultrazol - Fuel Additive	1,500	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Summary of Work

TANK #3 (91) FILL SUMP

-INSTALL OPW SPILL BUCKET RETROFIT KIT TO CONVERT EXISTING SINGLEWALL FILL BUCKET TO DOUBLEWALL, PART# 1C3712D

-REPLACE OPW DROP TUBE LIKE FOR LIKE, PART# 71SO-420C.

-REPLACE 4" STEEL FILL RISER (IF NEEDED).

TANK #4 (ADDITIVE) FILL SUMP

-INSTALL OPW SPILL BUCKET RETROFIT KIT TO CONVERT BOTH EXISTING SINGLEWALL FILL BUCKETS TO DOUBLEWALL. PART# 1C3712D, & 1C3712P.

-REPLACE DROP TUBE LIKE FOR LIKE, OPW 61FSTOP-2000.

-REPLACE 4" STEEL FILL RISER (IF NEEDED).

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Jones Covey Group Inc
9595 Lucas Ranch Road #100
Rancho Cucamonga, CA 91730

Contact Person: Donovan Davila
Phone: 714/975-4257
Email: rsills@jonescovey.com
Contractor License # IL002414 Exp. 2/10/2025

Sincerely,



Daniel Starks