



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2009002
Permit #: 01270-2023UPG
Request Rec'd: 11/01/2023
Approval Date: 11/01/2023
Permit Expires: 05/01/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 3330 Kimball Real Estate, Inc. 515 Alive Drive Northbrook, IL 60062 Cook County Contact: Binu Poonthurail 847/644-9869	FACILITY - name and address where tanks are located: 3330 Kimball, Inc. 3330 N. Kimball Ave. Chicago, IL 60618 Cook County Contact: Binu Poonthurail 847/644-9869
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	New
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection

Summary of Work

DISCONNECT EXISTING STEEL PIPING. REMOVING EXISTING TOKHEIM SUBMERSIBLE PUMP. FURNISH AND INSTALLING ONE (1) OPW FIBERGLASS TANK SUMP, ONE (1) RED JACKET 3/4HP SUBMERSIBLE PUMP WITH MECHANICAL LEAK DETECTOR. RECONNECT EXISTING PIPING INSIDE NEW TANK SUMP.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Superior Petroleum Marketers, Inc. 2336 Albright Lane P. O.Box 4648 Wheaton, IL 601894648	Contact Person: Steve Tuttle Phone: 630/588-1198 Email: tuttle.steve11@gmail.com Contractor License # IL2087 Exp. 2/4/2024

Sincerely,

Raul Valdivia

For Office Use Only

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing