



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 7011098
Permit #: 01279-2023UPG
Request Rec'd: 11/02/2023
Approval Date: 11/05/2023 DS
Permit Expires: 05/07/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Kinkaid-Reeds Creek Conservancy District 1763 Water Plant Road Murphysboro, IL 62966 Jackson County Contact: Scott Wilmouth 618/687-1722	FACILITY - name and address where tanks are located: Kinkaid Marina 2063 Marina Road Murphysboro, IL 62966 Jackson County Contact: Scott Wilmouth 618/687-1722
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Non Ethanol	10,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall A.P.T. Poly Tech P175SC	Replacing - Piping - Flexible Double Wall
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 600 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Incon TS 1001 with SCALD
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors

Dispensers on the Permit

Dispenser	Action
1/2	Replacing - 1/2

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

Install new product piping from the STP to dispenser 1/2 under the canopy and from the STP to the transition sump at the shore line. The existing marina product piping on the fueling dock will remain. Incon EVO 600 with SCALD will be installed. The existing product piping will be removed by another contractor.

Special Contingencies

Replaced piping exceeds 20 feet or 50% of the total pipe run.

PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service
128 Millwell Drive
Maryland Heights, MO 63043

Contact Person: Terry Smith
Phone: 314/267-1231
Email: terrys@unitedpetro.com
Contractor License # IL002402 Exp. 2/10/2024

Sincerely,



Daniel Starks