



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 2029725
Permit #: 01283-2023UPG
Request Rec'd: 11/06/2023
Approval Date: 11/06/2023 DS
Permit Expires: 05/07/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Mehbood Ali Irshad Khan 6405 N. Campbell Chicago, IL 60645 Cook County Contact: Rashard Khan 773/888-7289	FACILITY - name and address where tanks are located: Bucky's Express #508 799 E. Nerge Road Roselle, IL 60172 Du Page County Contact: Sri Karne 708/307-0075
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Regular	10,000	Currently in use	Federal
4	Gasoline - Premium	10,000	Currently in use	Federal

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Summary of Work

Installing containment under dispenser one and two and forming new island

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Reliable Pump Service and Maintenance 14007 S Bell Road Suite 228 Homer Glen, IL 60491	Contact Person: John Baio, Jr. Phone: 815/546-7867 Email: Reliablepumpservice@yahoo.com Contractor License # IL002433 Exp. 10/7/2024

Sincerely,

Daniel Starks

For Office Use Only

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing