



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

Permit for Emergency Repair Request on 11/13/2023

FOR OFFICE USE ONLY

Facility #: 2047583
Permit #: 01304-2023UPG
Request Rec'd: 11/13/2023
Approval Date: 11/13/2023 DS
Permit Expires: 11/26/2023

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR TEN WORKING DAYS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Thorntons LLC 2600 James Thornton Way Louisville, KY 40245 Jefferson County Contact: Maggie Seagh 502/425-8022	FACILITY - name and address where tanks are located: Thornton's Store #356 500 West Maple Street New Lenox, IL 60451 Will County Contact: Compliance Department 502/425-8022
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	6,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping	Replacing - Piping - Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping

Summary of Work

Replace 8 foot section of piping that was damaged by the village in the south east corner of the tank area.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/243-9081 Email: Steve@andersonpump.com Contractor License # IL002275 Exp. 5/21/2024

Sincerely,

Daniel Starks