



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	3029306
Permit #:	01308-2023CAT
Request Rec'd:	11/13/2023
Approval Date:	11/13/2023 DS
Permit Expires:	05/14/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: S & K Mini Mart, LLC 4400 Kennedy Dr. East Moline, IL 61244 Rock Island County Contact: Kiram Basnet 309/792-3457	FACILITY - name and address where tanks are located: S & K - 2 Mini Mart Inc. 4400 Kennedy Drive East Moline, IL 61244 Rock Island County Contact: Sushil Khadka 309/792-3457
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Mid-grade	8,000	Currently in use	Federal
3	Gasoline - Premium	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

The Cathodic Protection Inspection readings for the Regular, Mid-grade, Premium, and Dispenser 5/6 Piping at the STP FAILS due to the readings being below the minimum requirements of a negative polarization of at least -0.850 millivolts.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Protanic, LLC
658 North Progress Drive PO Box 80265
Saukville, WI 53080

Contact Person: Kylie Krombach
Phone: 262/268-1150
Email: stuartr@protanicinc.com
Contractor License # IL1413 Exp. 9/26/2024

Sincerely,



Daniel Starks