



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY

Facility #: 2047671
Permit #: 01280-2023REM
Request Rec'd: 11/03/2023
Amended Date: 11/14/2023 Chi
Approval Date: 11/06/2023
Permit Expires: 05/07/2024

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Northwestern Memorial Healthcare 211 E. Ontario St., Suite 800 Chicago, IL 60611 Contact: Charles Cloutier 630/933-5609	FACILITY - name and address where tanks are located: Northwestern Memorial Healthcare 4822 South Cottage Grove Chicago, IL 60615 Cook County Contact: Charles Cloutier 630/933-5609
--	--

Tanks on the Permit

Tank #	Capacity	Product	Last Used Date
1	550	Heating Oil	12/31/1973
2	550	Heating Oil	12/31/1973

Summary of Work

Tank and piping will be removed.

Special Contingencies

Amendment Reason:

Amended to add an additional 550-gallon pre-74 heating oil tank uncovered at the site.

The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 708/308-8217 Email: ademauro@rwcollins.com Contractor License # IL772 Exp. 2/9/2024

Sincerely,

Seán Keane

Raul Valdivia