



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**

Facility #: 2006903  
Permit #: 01093-2023UPG  
Request Rec'd: 09/25/2023  
Amended Date: 11/16/2023 DS  
Approval Date: 09/25/2023 DS  
Permit Expires: 03/26/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Roosevelt & Cicero Property, LLC 4809 W. Roosevelt Road Cicero, IL 60804 (None) County Contact: Ammar Alesayi 708/655-9265	<b>FACILITY</b> - name and address where tanks are located: Cicero Food & Fuel, Inc. 4801 W. Roosevelt Rd. Cicero, IL 60804 Cook County Contact: Ammar Alesayi 708/655-9265
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	E85	8,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Flexible Double Wall NUPI Smartflex
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor

**Dispensers on the Permit**

Dispenser	Action
3/4	Sump / Sensors Changing

**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

**Summary of Work**

Converting Tank #3 to E85 and running a dedicated line to dispenser 3/4 from that tank. The existing RUL line from Tank #1 will be disconnected from Tank #3 and run continuous as is to the dispensers.

**Special Contingencies**

**Amendment Reason:**

Spill container was NOT replaced.

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company  
2939 175th Street  
Lansing, IL 60438

Contact Person: Ed Angell  
Phone: 708/474-3344  
Email: dj.white@bkequip.com  
Contractor License # IL1207 Exp. 2/14/2024

Sincerely,



---

Daniel Starks