



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	3026528
Permit #:	01203-2023UPG
Request Rec'd:	10/18/2023
Amended Date:	11/16/2023 DS
Approval Date:	10/18/2023 DS
Permit Expires:	04/18/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: AM PM 125, Inc. 1012 E. Broadway P.O. Box 855 Astoria, IL 61501 (None) County Contact: Gopal Basnet 217/306-2920	FACILITY - name and address where tanks are located: AM PM 125, Inc. 1012 East Broadway P.O. Box 93 Astoria, IL 61501 Fulton County Contact: Everest Thapa 512/818-7199
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	6,000	Currently in use	Federal
2	Gasoline - Premium	4,000	Currently in use	Federal
3	Diesel Fuel	4,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Piping	Single Wall STP/Tanktop Sump	New
Leak Detection - Piping	Sump Sensor with positive shutdown	New
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Flexible Double Wall OPW Pisces	Replacing - Piping - Fiberglass Single Wall Piping A.O. Smith

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Flexible Double Wall OPW Pisces	Replacing - Piping - Fiberglass Single Wall Piping A.O. Smith

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Piping	Single Wall STP/Tanktop Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Flexible Double Wall OPW Pisces	Replacing - Piping - Fiberglass Single Wall Piping A.O. Smith

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

REMOVING EXISTING SINGLE WALL SPILL BUCKETS AND REPLACING WITH DOUBLEWALL SPILL BUCKET.
 SINGLE WALL SPILL BUCKETS FAILED INSPECTION.
 REPLACING PIPING AND INSTALLING SUMPS.

Special Contingencies

Replaced piping exceeds 20 feet or 50% of the total pipe run.

Amendment Reason:

REPIPE STATION AND INSTALL NEW SUMPS AND PIPE LEAD TIME ON THE APT PIPING IS TO FAR OUT. NEED TO CHANGE TO OPW PIPING

PERSON, FIRM OR COMPANY PERFORMING WORK:

R. L. Hoener Company
 2923 Gardner Expressway P. O. Box 1086
 Quincy, IL 62305

Contact Person: Marty Jackson
 Phone: 217/223-2190
 Email: KMAJORS@RLHOENER.COM
 Contractor License # IL2021 Exp. 5/22/2024

Sincerely,



Daniel Starks

For Office Use Only**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing