



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**

Facility #: 4046446  
Permit #: 01344-2023UPG  
Request Rec'd: 11/21/2023  
Approval Date: 11/21/2023 DS  
Permit Expires: 05/21/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County Contact: Zachary Davis 937/203-7827	<b>FACILITY</b> - name and address where tanks are located: Speedway #7503 1300 W. Fayette Ave. Effingham, IL 62401 Effingham County Contact: Michelle Swindell 708/444-7086
--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	E85	6,000	Currently in use	Federal
2	Gasoline - Premium	6,000	Currently in use	Federal
3	B-11	12,000	Currently in use	Federal
4	Gasoline - Regular	20,000	Currently in use	Federal
5	B-11	20,000	Currently in use	Federal
6	B-11	20,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Removing

**Summary of Work**

removing overfill alarm as the tanks have OPV drop tubes installed

**Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2024

Sincerely,



Daniel Starks