



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 1006893
Permit #: 01352-2023UPG
Request Rec'd: 11/22/2023
Approval Date: 11/22/2023 DS
Permit Expires: 05/22/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Illinois Department of Military Affairs 1301 N. MacArthur Blvd. Springfield, IL 627022399 Sangamon County Contact: Mr.Edson Rocha 217/761-3684	FACILITY - name and address where tanks are located: UTES Marseilles 2543 North 23rd Rd. Marseilles, IL 61341 LaSalle County Contact: Paul Gaspardo 815/750-6530
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Ultra Low Sulfur Diesel	6,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

Dispensers on the Permit

Dispenser	Action
3	Sump / Sensors Changing
3	Replacing - 3

Dispenser 3 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
🔍 Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

Installing new single wall Bravo under dispenser sump at dispenser #3
Installing sensor with positive shut down
re-using existing dispenser
Installing new island

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 630/878-6354
Email: jasonre@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2024

Sincerely,



Daniel Starks