



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3035522
Permit #: 01354-2023CAT
Request Rec'd: 11/24/2023
Approval Date: 11/26/2023 DS
Permit Expires: 05/29/2024

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Jay Ambe Management, LLC 3209 W. Cypress Creek Drive Dunlap, IL 61611 (None) County Contact: Ravi Patel 646/691-0060	FACILITY - name and address where tanks are located: Santok #3, Inc. 12200 North Brentfield Road, Suite 6 Dunlap, IL 61525 Peoria County Contact: Shalin Patel 309/453-1058
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	10,000	Currently in use	Federal
2	Gasoline - Mid-grade	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	STP - Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	STP - Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Replacing failed anodes on STP Flex connectors with new 5lb anodes

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Midwest Tank Testing Company 326 Eiler Drive Gifford, IL 61847	Contact Person: Stephen Hall Phone: 217/714-4305 Email: midwesttanktestingsth@aol.com Contractor License # IL752 Exp. 3/17/2025

Sincerely,

Daniel G. Starks

Daniel Starks