



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2047685
Permit #: 01368-2023ABN
Request Rec'd: 11/28/2023
Approval Date: 11/28/2023
Permit Expires: 05/29/2024

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Sipi Metals Corp 1720 Elston Ave Chicago, IL 60622 Cook County Contact: Kelly Coyle 312/276-0076	FACILITY - name and address where tanks are located: Sipi Metals Corp. Warehouse 1020 W. 119th Street Chicago, IL 60643 Cook County Contact: Ryan McCracken 248/730-4850
--	---

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
1	4,000	Waste Oil	Inert material mixed with portland cement	
2	10,000	Waste Oil	Inert material mixed with portland cement	
3	4,000	Waste Oil	Inert material mixed with portland cement	
4	6,000	Waste Oil	Inert material mixed with portland cement	

Explanation of Waiver for Abandonment

Abandonment of 4 USTs due to proximity to building foundations and inaccessibility. (See attached map) Tanks 1 and 2 are within 5' of the building foundation and near gas line. Tanks 7 and 8 are located in an enclosed and fenced courtyard with no excavator access.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2024

Sincerely,

Sean Keane