



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 1028855
Permit #: 01371-2023UPG
Request Rec'd: 11/22/2023
Approval Date: 11/28/2023 DS
Permit Expires: 05/29/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: GPM Midwest 18, LLC 8565 Magellan Pkwy, Ste. 400 Richmond, VA 23227 (None) County Contact: Chad Fluck 317/914-9446	FACILITY - name and address where tanks are located: Fas Mart #564 8209 Burden Rd. Machesney Park, IL 61115 Winnebago County Contact: Diane Campasano 804/730-1568Ext.1208
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Premium	10,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

Dispensers on the Permit

Dispenser	Action
5/6	Sump / Sensors Changing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump

Summary of Work

Replacing 5/6 UDC due to fiberglass pipe leak repair. Replacing all shear valves and flex connectors. Precision line tests and UDC hydro test.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/209-0640 Email: natem@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2024

Sincerely,

Daniel G. Starks

Daniel Starks

For Office Use Only

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed	Review