

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2027515
Permit #: 01372-2023CAT
Request Rec'd: 11/28/2023
Approval Date:11/29/2023 DS
Permit Expires: 05/29/2024

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Club Property, LLC 8550 S. Harlem Suite G Bridgeview, IL 60455

Cook County

Contact: Mohammed Abdullah 773/447-2771

FACILITY

- name and address where tanks are located:

Country Club Hills Gas 18280 S Pulaski Road Country Club Hills, IL 60478

Cook County

Contact: Jeoji Cherian 847/845-7642

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	11,097	Currently in use	Federal
2	Gasoline - Mid-grade	11,097	Currently in use	Federal
3	Gasoline - Premium	10,152	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection -	STP - Sacrificial Anode Flex	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex
Piping	Connector	Connector - STP

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection -	STP - Sacrificial Anode Flex	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex
Piping	Connector	Connector - STP

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection -	STP - Sacrificial Anode Flex	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex
Piping	Connector	Connector - STP

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Installing sacrificial anodes on steel piping in all 3 STP sumps.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC 1058 National Parkway Schaumburg, IL 601734519 Contact Person: Chris Derro Phone: 708/717-2676

Email: cderro@cardinalcompliance.net

Contractor License # IL002418 Exp. 3/21/2025

Sincerely, Caniel J. Starks

Daniel Starks