



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2022735
Permit #: 01376-2023REM
Request Rec'd: 11/29/2023
Approval Date: 11/29/2023
Permit Expires: 05/29/2024

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to remove underground storage tank piping is hereby granted. Such removal must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site. After the removal is completed, the owner/operator shall have a site assessment performed by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Ghulam Qadir 6939 North Keating Lincolnwood, IL 60712 Cook County Contact: Ghulam Qadir 773/671-0427	FACILITY - name and address where tanks are located: Shell 9955-8 South Western Avenue Chicago, IL 60643 Cook County Contact: Ghulam Qadir 773/779-2881
--	--

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Last Used Date
5	12,000	Gasoline - Regular	
6	8,000	Gasoline - Premium	
7	8,000	Diesel Fuel	

Summary of Work

REMOVING PRODUCT PIPING ONLY. VENTS TO REMAIN. AN UPGRADE TO REPLACE PIPING WILL FOLLOW.

Special Contingencies

After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Cardinal Compliance LLC 1058 National Parkway Schaumburg, IL 601734519	Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2025

Sincerely,

Sean Keane