



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2022735
Permit #: 01377-2023UPG
Request Rec'd: 11/29/2023
Approval Date: 11/30/2023
Permit Expires: 05/30/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Ghulam Qadir 6939 North Keating Lincolnwood, IL 60712 Cook County Contact: Ghulam Qadir 773/671-0427	FACILITY - name and address where tanks are located: Shell 9955-8 South Western Avenue Chicago, IL 60643 Cook County Contact: Ghulam Qadir 773/779-2881
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Currently in use	Federal
6	Gasoline - Premium	8,000	Currently in use	Federal
7	Diesel Fuel	8,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000/L
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	New

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000/L
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	New

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall NUPI Smartflex	Replacing - Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000/L
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	New

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

REPLACING PIPING AND INSTALLING 4 NEW UDC'S USING EXISTING TANK SUMPS. ADDING SENSORS AS REQUIRED.

Special Contingencies


Replaced piping exceeds 20 feet or 50% of the total pipe run.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
1058 National Parkway
Schaumburg, IL 601734519

Contact Person: Chris Derro
Phone: 708/717-2676
Email: cderro@cardinalcompliance.net
Contractor License # IL002418 Exp. 3/21/2025

Sincerely,



Sean Keane

For Office Use Only**Dispenser 3/4 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing