



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 3029306
Permit #: 01392-2023UPG
Request Rec'd: 12/04/2023
Approval Date: 12/04/2023 DS
Permit Expires: 06/04/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: S & K Mini Mart, LLC 4400 Kennedy Dr. East Moline, IL 61244 Rock Island County Contact: Kiram Basnet 309/792-3457	FACILITY - name and address where tanks are located: S & K - 2 Mini Mart Inc. 4400 Kennedy Drive East Moline, IL 61244 Rock Island County Contact: Sushil Khadka 309/792-3457
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Mid-grade	8,000	Currently in use	Federal
3	Gasoline - Premium	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Incon TS 1001 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik 950

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Incon TS 1001 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik 950

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Incon TS 1001 with SCALD	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik 950

Summary of Work

Replacing existing AutoStik JR. ATG with Incon TS-1001. New Probes to be installed.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Illowa Enterprises, Inc.
2703 4th Avenue
Moline, IL 61265

Contact Person: James Saddoris
Phone: 309/762-1729
Email: illowa@illowaent.com
Contractor License # IL981 Exp. 5/1/2024

Sincerely,



Daniel Starks