

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov Amended FOR OFFICE USE ONLY

Facility #: 2006372
Permit #: 01375-2023ABN
Request Rec'd: 11/29/2023
Amended Date:12/04/2023 DS
Approval Date: 11/29/2023 DS
Permit Expires: 05/29/2024

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Woodlake Pacific Holdings, LLC 1225 W. Lake Street Melrose Park, IL 60610 (None) County

Contact: Joe Ottolino 630/667-6890

FACILITY

- name and address where tanks are located:

Woodlake Specialty Hospital 1225 Lake Street Melrose Park, IL 60160 Cook County

Contact: Jimmy Parren 630/846-1361

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
3	20,000	Diesel Fuel	Inert material mixed with portland cement	

Explanation of Waiver for Abandonment

Tank to be abandoned is adjacent to an existing 4,000 gallond diesel tank that is in use for generator fueling. Also has been found that part of the piping from the tank to be abandoned runs over the adjacent tank and next to the piping from that tank. Would like to abandon in place the part of the piping that goes over the tank and along site the piping to remain

Special Contingencies

Amendment Reason:

When uncovering the piping to prepare for the piping removal, we found that the piping for the tank to be abandoned runs over the top of the adjacent tank thus making it impossible to remove without working over the adjacent tank and piping from the adjacent tank

PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 630/878-6354
Email: jasonre@rstenstrom.com
Contractor License # IL1890 Exp. 3/7/2024

Sincerely,

Daniel Starks

Vaniel J. Starke