



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2007015
Permit #: 01409-2023UPG
Request Rec'd: 12/05/2023
Approval Date: 12/05/2023
Permit Expires: 06/05/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Mara Food Stores, Inc. 7900 S. Lafayette Ave. Chicago, IL 60620 Cook County Contact: Ahmed Minhaj 312/286-9677	FACILITY - name and address where tanks are located: Falcon Fuels 7900 S. Lafayette Ave. Chicago, IL 60620 Cook County Contact: Ahmed Minhaj 312/286-9677
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Diesel Fuel	5,000	Currently in use	Federal

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 300 with CSLD
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Submersible Pump	New
Piping	Other Steel Riser	New
Piping	Ball Valves	New
Piping	Flex Connector Steel	New

Summary of Work

The Diesel fueling system will be converted to E85 product. The tank interstitial sensor, line leak detector, probe, overfill prevention drop tube, ball valve, and flex connector will be replaced with equipment compatible with E85 product. The tank monitor console will be replaced with a TLS 450Plus tank monitor with CSLD.


Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: ed@bkequip.com
Contractor License # IL1207 Exp. 2/14/2024

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive, flowing style. Below the signature is a solid horizontal line.

Sean Keane