

City of Chicago Department of Public Health 333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY Facility #: 2020321 Permit #: 01424-2023ABN Request Rec'd: 12/07/2023 Approval Date: 12/08/2023 Permit Expires:06/10/2024

# Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

## THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| OWNER OF TANKS<br>- Corporation, partnership, or other business entity: | FACILITY - name and address where tanks are located:               |
|---|--|
| 1200B, Inc.<br>1200 West Belmont<br>Chicago, IL 60657<br>Cook County    | 1200B, Inc.<br>1200 W. Belmont<br>Chicago, IL 60657<br>Cook County |
| Contact: George Nediyakalayil 773/549-8522                              | Contact: George Nediyakalayil 773/549-8522                         |

#### **Tanks on the Permit**

| Tank # | Capacity | Product            | Fill Material                             | Comments |
|--------|----------|--------------------|---|----------|
| 11     | 300      | Gasoline - Regular | Inert material mixed with portland cement |          |

## **Explanation of Waiver for Abandonment**

ABN of UST due to location of ATT box and cable directly over tank

## **Special Contingencies**

| RSON, FIRM OR COMPANY PERFORMING WORK:                           |   |  |
|--|---|--|
| RW Collins Company<br>7225 West 66th Street<br>Chicago, IL 60638 | Contact Person: Lisa Kruse<br>Phone: 779/301-5966<br>Email: slucero@rwcollins.com<br>Contractor License # IL772 Exp. 2/9/2024 |  |

Sincerely,

Sean Keane