



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2043633  
Permit #: 01413-2023UPG  
Request Rec'd: 12/06/2023  
Approval Date: 12/08/2023  
Permit Expires: 06/10/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: LOC Gas, Inc. 1224 W. 59th Street Chicago, IL 60636 Cook County Contact: Sadia Aslam 872/888-5744	<b>FACILITY</b> - name and address where tanks are located: GB Gas Inc. 1224 W. 59th Street Chicago, IL 60636 Cook County Contact: Zaib Jahangir 872/888-5744
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
2	Gasoline - Premium	8,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW EECO 1500 with CITLDS
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor


**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW EECO 1500 with CITLDS
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors


## Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing


### Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
 Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor


### Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
 Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

### Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
 Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

### Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
 Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor


## Summary of Work

Replacing tank monitor, probes, and sensors.

## Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 2/14/2024

Sincerely,



Sean Keane