



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**

Facility #: 2023011  
Permit #: 01408-2023UPG  
Request Rec'd: 12/05/2023  
Amended Date: 12/12/2023 Chi  
Approval Date: 12/05/2023  
Permit Expires: 06/05/2024

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Ansemoss & Sons Inc 1004 S. Des Plaines Ave. Chicago, IL 60607 Cook County Contact: Tony Haddad 312/617-1243	<b>FACILITY</b> - name and address where tanks are located: Tony's Citgo 1004 S. Des Plaines Ave. Chicago, IL 60607 Cook County Contact: Joe Nahhas 312/554-1236
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Diesel Fuel	10,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Piping	Steel Single Wall Piping	Replacing - Piping - Steel Single Wall Piping
Piping	Ball Valves	New
Piping	Flex Connector Steel	New
Piping	Other Submersible Pump	New

**Summary of Work**

Replace Diesel STP and sump along with piping to get the new sump in. Replace wireless line leak with mechanical.


**Special Contingencies**

**Amendment Reason:**

Customer has single wall pipe so we will not install a sensor in the sump as it is not required.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 708/560-5590 Email: keith@andersonpump.com Contractor License # IL002275 Exp. 5/21/2024

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive style with a horizontal line underneath the text.

Sean Keane